

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1429:102 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Secutron Inc., 70 Esna Park Dr., Unit 14, Markham, Ontario Canada, L3R 6E7
Contact: *Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Model MR-2400 fire alarm control unit. Power-limited; non-coded, local, manual, automatic, waterflow, central station (protected premises) and sprinkler supervisory service. Also suitable for releasing service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

MR-2400	Control Unit
MR-2905	Power Supply

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

*Rev. 09-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**